



Certificate G59/2

Engineering Recommendation

Manufacturer: Jiangsu GoodWe Power Supply Technology Co., Ltd.
Address: No.189 Kun Lun Shan Road, Suzhou New District, Jiangsu
Tel: +86 512 6239 7998
Fax: +86 512 6239 7972
Post Code: 215163
Country: China

Test house details: Jiangsu GoodWe Power Supply Technology Co., Ltd.
R&D Department
Email: service@goodwe.com.cn

Type reference: GoodWe String Inverters GW4200-DS, GW4600-DS
Max AC power: 4400W/5100W
Nominal AC power: 4200W/4600W

The results of the G59/2 tests are summarized in this certificate. GoodWe declares hereby that all units shipped to the UK comply with the specifications and parameters defined in G59/2 engineering recommendation. These settings cannot be changed by installer, user or by anyone other than GoodWe. Complete documentation on test details are available at GoodWe on demand.

Test details

- Harmonic current emissions according to BS EN 61000-3-2A
- Voltage fluctuations and flicker according to BS EN 61000-3-3A
- DC injection / Power factor
- Under / Over frequency tests
- Under / Over voltage tests
- Loss of mains test
- Reconnection time

Jiangsu GoodWe Power Supply Technology Co., Ltd.
Suzhou, 28/04/2012

Zhang Kun
Manager of Technical Support Department

A handwritten signature in black ink that reads "Zhang Kun".